Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZM757

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HERMANSON, JEFF			Phone #: (920)858-8225
Mailing Address: 1424 N HARRIMAR ST			
City: APPLETON	State: WI	Zip Code: 54911	
County: Forest	Co. Permit #:	Notification #: 8919826901	Completed: 10-04-2022

Well Constructor (Business Name): KLEIMAN, ERIK P	Lic. #: 6720	Facility ID # (Public Wells):	
Address: KLEIMAN PUMP & WELL DRLG PO BOX 704 IRON MOUNTAIN MI 49801-0704		Well Plan Approval #:	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.2	

1. Well Location

Town of BLACKWELL

Fire # (if avail.): 6277

Street Address or Road Name and Number: CLEMENS LN

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
45.5993 °N	-88.4287 °W			GPS008

NE SE or Govt Lot #	Section	Township	Range
	13	36 N	16 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	240

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S	Z	S-SAND Z-W/COBBLES/BOULDERS	Surface	25
		Z		Z-CLAY & GRAVEL	25	62.75
G		Q		G-GRAY Q-GRANITE	62.75	100
G		Q		G-GRAY Q-GRANITE	100	240

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL SCH 40 WHEATLAND WELDED	Surface	61.75
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method: DRIVEN DRY, CHIPS

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE	Surface	61.75	4 S

9. Static Water Level

10 ft. below ground surface

10. Pump Test

Pumping level 240 ft. below surface

Pumping at 48 GP M for 0.5 Hrs.

Pumping Method ? Airlift

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? No

N/A

13. Constructor / Supervisory Driller	Lic #	Date Signed
EK	6720	10-04-2022
Drill Rig Operator	Lic or Reg #	Date Signed
LK	8882	10-04-2022

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Privy		130

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	10/04/2022	DELAYED WATER SAMPLING

Created On: 12-02-2022 Updated On: 08-11-2023 Review Status: APPROVED