

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZM759		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner SCHNEIDER, COLIN				Phone # (906)282-9558		1. Well Location				Fire # (if avail.)	
Mailing Address 2224 RIVER DR						Town of AURORA				2224	
City NIAGARA				State WI Zip Code 54151		Street Address or Road Name and Number RIVER DR					
County Florence		Co. Permit #		Notification # 8931703401		Completed 10-28-2022		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) KLEIMAN, ERIK P				Lic. # 575		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.8024 °N -88.1087 °W		Method Code GPS008	
Address KLEIMAN PUMP & WELL DRLG PO BOX 704 IRON MOUNTAIN MI 49801-0704				Well Plan Approval #		NW NE Section Township Range or Govt Lot # 3 38 N 19 E		2. Well Type New Well			
Hicap Permanent Well #				Common Well #		Specific Capacity 0.7		Reason for replaced or reconstructed well ?			
3. Well serves 1 # of HOME Private,potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No		Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock		
6		Surface		43		No Rotary - Mud Circulation No Yes Rotary - Air Yes No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)					
8. Geology											
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
Y		Y-SAND & GRAVEL				Surface		20			
C		C-CLAY				20		30			
E S		E-CLEAN S-SAND				30		43			
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)			
6		STEEL SCH 40 WHEATLAND WELDED				Surface		40.25			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
6		SS 24 SLOT				39		43			
7. Grout or Other Sealing Material											
Method BENTONITE DRIVEN DRY											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement			
BENTONITE				Surface		40.25		3 S			
9. Static Water Level											
8 ft. below ground surface											
10. Pump Test											
Pumping level 35 ft. below surface											
Pumping at 20 GP M for 0.5 Hrs.											
Pumping Method ? Airlift											
11. Well Is											
24 in. above grade											
Developed ? Yes Disinfected ? Yes Capped ? Yes											
12. Notified Owner of need to fill & seal ? Yes											
Filled & Sealed Well(s) as needed? No N/A											
13. Constructor / Supervisory Driller				Lic #		Date Signed					
EH				6720		11-04-2022					
Drill Rig Operator				Lic or Reg #		Date Signed					
LK				8882		11-04-2022					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)		300	Septic or Holding, or POWTS Tank		111

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	10/28/2022	DELAYED WATER SAMPLING

Created On: 12-02-2022

Updated On: 08-11-2023

Review Status: APPROVED