

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZN862		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner AGAMAITE, CHADC						Phone # (920)748-8231		1. Well Location				Fire # (if avail.)									
Mailing Address W11349 OLDEN RD						Town of WORCESTER						W5151									
City RIPON						State WI		Zip Code 54971				Street Address or Road Name and Number W5151 CO RD H									
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #							
Price				8888838901		08-29-2022															
Well Constructor (Business Name) KARNOSH, DONALD F				Lic. # 660		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.7423 °N -90.3006 °W				Method Code GPS008							
Address KARNOSH WELL DRILLING W7244 S MINNOW LAKE RD PHILLIPS WI 54555				Well Plan Approval #				NE NW		Section 36		Township 38 N		Range 1 E							
				Approval Date (mm-dd-yyyy)				or Govt Lot #													
Hicap Permanent Well #				Common Well #		Specific Capacity 3				2. Well Type New Well				of previous unique well #		constructed in					
3. Well serves 1 # of CABIN				Hicap Well ? No				Reason for replaced or reconstructed well ?				Construction Type Drilled									
Private, potable				Hicap Property ? No																	
Heat Exchange ___ # of drillholes				Hicap Potable ? No																	
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		48		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)						R P G R-RED P-HARDPAN G-W/GRAVEL/STONES R N S R-RED N-FINE S-SAND Y U Y-SAND & GRAVEL U-MUDDY OR MURKY E Y E-CLEAN Y-SAND & GRAVEL		Surface 12 40 43 43		12 40 43 48					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		21 ft. below ground surface				24 in. above grade							
6		STEEL 18.97 LB A-53 NUCOR NTP TRI PE				Surface		46		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 26 ft. below surface				Disinfected ? Yes							
4		CONT STAINLESS 20 SLOT				46		48		Pumping at 15 GP M for 2 Hrs.				Capped ? Yes							
7. Grout or Other Sealing Material														Pumping Method ? Test Pump				12. Notified Owner of need to fill & seal ? No Filled & Sealed Well(s) as needed? No			
Method MOUNDED																					
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement															
GRANULAR BENTONITE		Surface		48		1 S															
13. Constructor / Supervisory Driller														Lic #		Date Signed					
DK														660		09-25-2022					
Drill Rig Operator														Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)		100	Privy		85

Comment:

A COMPLETE WCR WAS NOT RECEIVED FROM WELL CONSTRUCTOR.

6/24/24 NON ISSUED - FAILURE TO RESPOND TO REQUESTS FOR ADDITIONAL INFORMATION
7/19/2024 - ADDITIONAL INFORMATION PROVIDED.

Created On: 01-19-2023

Updated On: 07-22-2024

Review Status: APPROVED