Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZN863

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BADGER HOUSING, MERKEL, BOB	Phone #: (715)305-2700
Mailing Address: PO BOX 896	
City: MARSHFIELD	State: WI Zip Code: 54449
County: Price	Co. Permit #:
Notification #: 8904726901	Completed: 09-15-2022
Well Constructor (Business Name): KARNOSH, DONALD F	Lic. #: 660
Facility ID # (Public Wells):	
Address: KARNOSH WELL DRILLING W7244 S MINNOW LAKE RD PHILLIPS WI 54555	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 3	

1. Well Location

Town of ELK	Fire # (if avail.): N8770
Street Address or Road Name and Number: N8770 GOLF COURSE RD	
Subdivision Name:	Lot #: Block #:
Latitude / Longitude in Decimal Degree (DD): 45.6893 °N -90.4415 °W	Method Code: GPS008
SE NW or Govt Lot #:	Section: 13 Township: 37 N Range: 1 W

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: DRILLED NEW WELL

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	50

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R	Q	S		R-RED Q-CAVING S-SAND	Surface	27
G		C		G-GRAY C-CLAY	27	45
R		Y		R-RED Y-SAND & GRAVEL	45	50

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 18.97 A-53 NUCOR NTP-TRI PE	Surface	47.5
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
4	CONT STAINLESS 20 SLOT	47.5	50

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		1 S

9. Static Water Level

17 ft. below ground surface

10. Pump Test

Pumping level 22 ft. below surface

Pumping at 15 GP M for 4 Hrs.

Pumping Method ? Test Pump

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DK	660	09-25-2022
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)		150	POWTS dispersal component (soil absorption unit or mound)		85
			Septic or Holding, or POWTS Tank		75

Comment:

Created On: 01-19-2023 Updated On: 08-15-2023 Review Status: APPROVED