

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZN863		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner BADGER HOUSING, MERKEL, BOB						Phone # (715)305-2700		1. Well Location				Fire # (if avail.)									
Mailing Address PO BOX 896						Town of ELK						N8770									
City MARSHFIELD						State WI		Zip Code 54449				Street Address or Road Name and Number N8770 GOLF COURSE RD									
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #							
Price				8904726901		09-15-2022															
Well Constructor (Business Name)				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code									
KARNOSH, DONALD F				660				45.6893 °N -90.4415 °W				GPS008									
Address KARNOSH WELL DRILLING W7244 S MINNOW LAKE RD PHILLIPS WI 54555				Well Plan Approval #		SE NW		Section		Township		Range									
				Approval Date (mm-dd-yyyy)		or Govt Lot #		13		37 N		1 W									
Hicap Permanent Well #				Common Well #		Specific Capacity		2. Well Type Replacement													
						3		of previous unique well # constructed in													
3. Well serves 1 # of HOME				Hicap Well ?		No		Reason for replaced or reconstructed well ?													
Private, potable				Hicap Property ?		No		DRILLED NEW WELL													
Heat Exchange ___ # of drillholes				Hicap Potable ?		No		Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		50		No Rotary - Mud Circulation				No		R Q S		R-RED Q-CAVING S-SAND		Surface		27			
						No Rotary - Air				No		G C		G-GRAY C-CLAY		27		45			
						No Rotary - Air & Foam				No		R Y		R-RED Y-SAND & GRAVEL		45		50			
						No Drill-Through Casing Hammer															
						No Reverse Rotary															
						No Cable-tool Bit ___ in. dia...				No											
						No Dual Rotary				No											
						No Temp. Outer Casing ___ in. dia															
						No Removed? ___ depth ft. (If NO explain on back side)															
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		17 ft. below ground surface				20 in. above grade							
6		STEEL 18.97 A-53 NUCOR NTP-TRI PE				Surface		47.5		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 22 ft. below surface				Disinfected ? Yes							
4		CONT STAINLESS 20 SLOT				47.5		50		Pumping at 15 GP M for 4 Hrs.				Capped ? Yes							
7. Grout or Other Sealing Material														Pumping Method ? Test Pump							
Method MOUNDED														12. Notified Owner of need to fill & seal ?				Yes			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement													
GRANULAR BENTONITE				Surface				1 S		Filled & Sealed Well(s) as needed?				Yes							
13. Constructor / Supervisory Driller														Lic #		Date Signed					
DK														660		09-25-2022					
Drill Rig Operator														Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)		150	POWTS dispersal component (soil absorption unit or mound)		85
			Septic or Holding, or POWTS Tank		75

Comment:

Created On: 01-19-2023

Updated On: 08-15-2023

Review Status: APPROVED