

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZN864		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner SCHENK, DEREK				Phone # (920)946-8645		1. Well Location				Fire # (if avail.)	
Mailing Address 717 MADISON AVE						Town of FLAMBEAU				W9793	
City HOWARDS GROVE				State WI Zip Code 53083		Street Address or Road Name and Number W9793 WESLEYS RD					
County		Co. Permit #		Notification #		Completed		Subdivision Name		Lot # Block #	
Price				8918336601		09-30-2022					
Well Constructor (Business Name)				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)		Method Code	
KARNOSH, DONALD F				660				45.7884 °N -90.5623 °W		GPS008	
Address KARNOSH WELL DRILLING W7244 S MINNOW LAKE RD PHILLIPS WI 54555				Well Plan Approval #		NW SE Section Township Range or Govt Lot # 12 38 N 2 W		2. Well Type New Well			
Hicap Permanent Well #				Common Well #		Specific Capacity		Reason for replaced or reconstructed well ?			
						3.8					
3. Well serves 1 # of CAMPER				Hicap Well ? No				Construction Type Drilled			
Private,potable				Hicap Property ? No							
Heat Exchange ___ # of drillholes				Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology	
6		Surface		61		No Rotary - Mud Circulation		No		R S R-RED S-SAND Surface 15	
						No Rotary - Air		No		R P Z R-RED P-HARDPAN Z-W/COBBLES/BOULDERS 15 48	
						No Rotary - Air & Foam		No		Y U Y-SAND & GRAVEL U-MUDDY OR MURKY 48 58	
						No Drill-Through Casing Hammer				E S E-CLEAN S-SAND 58 61	
						No Reverse Rotary					
						No Cable-tool Bit ___ in. dia...		No			
						No Dual Rotary		No			
						No Temp. Outer Casing ___ in. dia					
						No Removed? ___ depth ft. (If NO explain on back side)					
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level	
6		STEEL 18.97 LB A-53 NUCOR NTP-TRI PE				Surface		59.5		24 ft. below ground surface	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test	
4		CONT STAINLESS 20 SLOT				59.5		61		Pumping level 28 ft. below surface	
7. Grout or Other Sealing Material											
Method MOUNDED											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		11. Well Is	
				Surface		61		1 S		20 in. above grade	
Filled & Sealed Well(s) as needed? No											
13. Constructor / Supervisory Driller											
DK				Lic #		660		Date Signed		10-15-2022	
Drill Rig Operator				Lic or Reg #		Date Signed					

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 01-19-2023

Updated On: 08-15-2023

Review Status: APPROVED