Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZN865

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DELASKY, JODY & WESLEY	Phone #: (715)820-1922
Mailing Address: N9705 PINE ISLE DR	
City: PHILLIPS	State: WI Zip Code: 54555

County	Co. Permit #	Notification #	Completed
Price		8938160201	11-02-2022

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
KARNOSH, DONALD F	660	

Address: KARNOSH WELL DRILLING W7244 S MINNOW LAKE RD PHILLIPS WI 54555

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well # | Common Well # | Specific Capacity: 2.1

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of WORCESTER

Fire # (if avail.): N9705

Street Address or Road Name and Number: N9705 PINE ISLE DR

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
45.7238 °N -90.4067 °W	GPS008

SE SW or Govt Lot #	Section	Township	Range
	31	38 N	1 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	48

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R		Y		R-RED Y-SAND & GRAVEL	Surface	23
G		P	C	G-GRAY P-HARDPAN C-CLAYEY	23	45
R		Y		R-RED Y-SAND & GRAVEL	45	48

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEE; 18.97 LB A-53 NUCOR NTTRL PE	Surface	48
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	48	1 S

9. Static Water Level
25 ft. below ground surface

10. Pump Test
Pumping level 32 ft. below surface
Pumping at 15 GP M for 3 Hrs.
Pumping Method ? Test Pump

11. Well Is
26 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DK	660	11-23-2022
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)	>	200	POWTS dispersal component (soil absorption unit or mound)		75
			Septic or Holding, or POWTS Tank		85

Comment:

Created On: 01-19-2023 Updated On: 08-15-2023 Review Status: APPROVED