

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZN865		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner DELASKY, JODY & WESLEY						Phone # (715)820-1922		1. Well Location				Fire # (if avail.)			
Mailing Address N9705 PINE ISLE DR						Town of WORCESTER						N9705			
City PHILLIPS						State WI		Zip Code 54555				Street Address or Road Name and Number N9705 PINE ISLE DR			
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #	
Price				8938160201		11-02-2022									
Well Constructor (Business Name) KARNOSH, DONALD F				Lic. # 660		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.7238 °N -90.4067 °W				Method Code GPS008			
Address KARNOSH WELL DRILLING W7244 S MINNOW LAKE RD PHILLIPS WI 54555				Well Plan Approval #		SE SW		Section 31		Township 38 N		Range 1 E			
				Approval Date (mm-dd-yyyy)		or Govt Lot #									
Hicap Permanent Well #		Common Well #		Specific Capacity 2.1		2. Well Type New Well				of previous unique well # constructed in					
3. Well serves 1 # of HOME				Hicap Well ? No		Reason for replaced or reconstructed well ?									
Private, potable				Hicap Property ? No											
Heat Exchange ___ # of drillholes				Hicap Potable ? No		Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		48		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)									
R		Y		C		R-RED Y-SAND & GRAVEL		Surface		23					
G		P		C		G-GRAY P-HARDPAN C-CLAYEY		23		45					
R		Y		C		R-RED Y-SAND & GRAVEL		45		48					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		STEE; 18.97 LB A-53 NUCOR NTTRL PE				Surface		48							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
GRANULAR BENTONITE				Surface		48		1 S							
9. Static Water Level															
25 ft. below ground surface															
10. Pump Test															
Pumping level 32 ft. below surface															
Pumping at 15 GP M for 3 Hrs.															
Pumping Method ? Test Pump															
11. Well Is															
26 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? No															
Filled & Sealed Well(s) as needed? No															
13. Constructor / Supervisory Driller															
DK				Lic #		660		Date Signed							
Drill Rig Operator				Lic or Reg #				Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)	>	200	POWTS dispersal component (soil absorption unit or mound)		75
			Septic or Holding, or POWTS Tank		85

Comment:

Created On: 01-19-2023

Updated On: 08-15-2023

Review Status: APPROVED