Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZO339

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	SCHREIER, PETER
Phone #	
Mailing Address	W8368 NORTH SHORE DR
City	ONALASKA
State	WI
Zip Code	54650

County	Co. Permit #	Notification #	Completed
La Crosse	2022085	8893039701	08-30-2022

1. Well Location

Town of ONALASKA

Fire # (if avail.): W8368

Street Address or Road Name and Number: W8368 NORTH SHORE DR

Subdivision Name	Lot #	Block #
HOMESTEAD ADD	24	2

Well Constructor (Business Name)	Lic. #
LYSAKER AND SONS WELL DRILLING AND SERVICE LLC	8941

Facility ID # (Public Wells):

Latitude / Longitude in Decimal Degree (DD): 43.9423 °N -91.323 °W

Method Code: SCR002

Well Plan Approval #:

SE	SW	Section	Township	Range
or Govt Lot #		15	17 N	8 W

Address: N5452 EAGLE CIRCLE LN W, ONALASKA WI 54650

Approval Date (mm-dd-yyyy):

2. Well Type Replacement

of previous unique well #: constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.5

Reason for replaced or reconstructed well ?: WATER SUPPLY

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	65

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	Y-SAND & GRAVEL	Surface	65

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW PE BLACK STEEL .237 WALL 10.79# ASTM A53B WHEATLAND WELDED	Surface	62
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3.5	STAINLESS STEEL 15 SLOT CONT	62	65

9. Static Water Level

28 ft. below ground surface

10. Pump Test

Pumping level 50 ft. below surface

Pumping at 12 GP M for 12 Hrs.

Pumping Method ? Airlift

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE CRUMBLES	Surface	62	1 S

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DL	8130	08-30-2022
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55	Sewer - Building Sanitary		15
Building Drain - Sanitary		10	Septic or Holding, or POWTS Tank		32

Comment:

Created On: 01-20-2023 Updated On: 08-15-2023 Review Status: APPROVED