

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZO344		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner HIGHER HOUSE PROP Phone #						1. Well Location				Fire # (if avail.)	
Mailing Address PO BOX 3692						Town of CAMPBELL				1749	
City LA CROSSE State WI Zip Code 54602						Street Address or Road Name and Number 1749 LA CRESENT ST					
County La Crosse		Co. Permit # 2022079		Notification # 9027285301		Completed 08-08-2022		Subdivision Name ISLAND PARADISE		Lot # 9	Block #
Well Constructor (Business Name) LYSAKER AND SONS WELL DRILLING AND SERVICE LLC				Lic. # 8941	Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.8516 °N -91.2637 °W			Method Code SCR002	
Address N5452 EAGLE CIRCLE LN W ONALASKA WI 54650				Well Plan Approval #		NE NW	Section 19	Township 16 N	Range 7 W		
				Approval Date (mm-dd-yyyy)		or Govt Lot #	19	16 N	7 W		
Hicap Permanent Well #		Common Well #		Specific Capacity 0.3		2. Well Type Replacement of previous unique well # constructed in					
3. Well serves 1 # of APARTMENT BUILDING Non-community Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No		Reason for replaced or reconstructed well ? WATER SUPPLY					
						Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole				Lower Open Bedrock				
4	Surface	67	No Rotary - Mud Circulation				No				
			No Rotary - Air				No				
			No Rotary - Air & Foam				No				
			No Drill-Through Casing Hammer								
			No Reverse Rotary								
			No Cable-tool Bit ___ in. dia...				No				
			No Dual Rotary				No				
			No Temp. Outer Casing ___ in. dia								
			No Removed? ___ depth ft. (If NO explain on back side)								
8. Geology											
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
Y		Y-SAND & GRAVEL				Surface		67			
6. Casing, Liner, Screen											
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)	To (ft.)					
4	NEW PE BLACK STEEL .237 WALL 10.79# ASTM A53B WHEATLAND WELDED				Surface	61					
Dia. (in.)	Screen type, material & slot size				From (ft.)	To (ft.)					
3.5	15 SLOT CONT STAINLESS STEEL				61	67					
7. Grout or Other Sealing Material											
Method MOUNDED											
Kind of Sealing Material			From (ft.)	To (ft.)	# Sacks Cement						
BENTONITE CRUMBLES			Surface	61	1 S						
9. Static Water Level											
15 ft. below ground surface											
10. Pump Test											
Pumping level 50 ft. below surface											
Pumping at 12 GP M for 12 Hrs.											
Pumping Method ? Test Pump											
11. Well Is											
18 in. above grade											
Developed ? Yes											
Disinfected ? Yes											
Capped ? Yes											
12. Notified Owner of need to fill & seal ? Yes											
Filled & Sealed Well(s) as needed? Yes											
TIM LYSAKER TO ABANDON											
13. Constructor / Supervisory Driller											
Lic #	Date Signed										
DL	8130	08-08-2022									
Drill Rig Operator	Lic or Reg #	Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Sewer - Collector - Sanitary		45	Building Drain - Sanitary		12
			Sewer - Building Sanitary		50

Comment:

Created On: 01-20-2023

Updated On: 06-18-2024

Review Status: APPROVED