Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZO467

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: KOHEGYI, JOE	Phone #: (715)776-4659
Mailing Address: 2512 CO J	
City: MERCER	State: WI — Zip Code: 54547

County	Co. Permit #	Notification #	Completed
Iron		9224217701	08-10-2023

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
MERCER WELL C.M.	8178	

Address: PO BOX 718 2809 CEMETARY ROAD LAC DU FLAMBEAU WI 54538

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.2

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of MERCER	Fire # (if avail.) 4270N

Street Address or Road Name and Number: WALLACE RD

Subdivision Name	Lot #	Block #
CABIN 4		

Latitude / Longitude in Decimal Degree (DD)	Method Code
46.1266 °N -90.1783 °W	GPS008

NE SE or Govt Lot #	Section	Township	Range
	12	42 N	2 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	155

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		S-SAND	Surface	25
		X		X-SAND & CLAY	25	38
		C		C-CLAY	38	120
		X		X-SAND & CLAY	120	150
	A	G		A-COARSE G-GRAVEL/STONES	150	155

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLK ASTM A53 WELDED 18.97 WHEATLAND	Surface	155
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	0.5	0.25 S

9. Static Water Level
9 ft. below ground surface

10. Pump Test
Pumping level 50 ft. below surface
Pumping at 10 GP M for 10 Hrs.
Pumping Method ? Test Pump

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
FS	4207	10-12-2024
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	=	40	POWTS dispersal component (soil absorption unit or mound)	>	120

Comment:

Created On: 12-06-2024 Updated On: 04-21-2025 Review Status: APPROVED