

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZO467		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner KOHEGYI, JOE						Phone # (715)776-4659		1. Well Location				Fire # (if avail.)			
Mailing Address 2512 CO J						Town of MERCER						4270N			
City MERCER						State WI		Zip Code 54547				Street Address or Road Name and Number WALLACE RD			
County Iron		Co. Permit #		Notification # 9224217701		Completed 08-10-2023		Subdivision Name CABIN 4				Lot # Block #			
Well Constructor (Business Name) MERCER WELL C.M.				Lic. # 8178		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 46.1266 °N -90.1783 °W				Method Code GPS008	
Address PO BOX 718 2809 CEMETARY ROAD LAC DU FLAMBEAU WI 54538				Well Plan Approval #		NE SE		Section 12		Township 42 N		Range 2 E			
				Approval Date (mm-dd-yyyy)		or Govt Lot #									
Hicap Permanent Well #		Common Well #		Specific Capacity 0.2		2. Well Type New Well									
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		Reason for replaced or reconstructed well ? Construction Type Drilled							
						Hicap Property ? No									
						Hicap Potable ? No									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) 6		From (ft.) Surface		To (ft.) 155		Upper Enlarged Drillhole				Lower Open Bedrock					
						No Rotary - Mud Circulation				No					
						No Rotary - Air				No					
						No Rotary - Air & Foam				No					
						Yes Drill-Through Casing Hammer									
						No Reverse Rotary									
						No Cable-tool Bit ___ in. dia...				No					
						No Dual Rotary				No					
						No Temp. Outer Casing ___ in. dia									
						No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)									
S		S-SAND		Surface		25									
X		X-SAND & CLAY		25		38									
C		C-CLAY		38		120									
X		X-SAND & CLAY		120		150									
A G		A-COARSE G-GRAVEL/STONES		150		155									
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		NEW BLK ASTM A53 WELDED 18.97 WHEATLAND				Surface		155							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
GRANULAR BENTONITE				Surface		0.5		0.25 S							
9. Static Water Level															
9 ft. below ground surface															
10. Pump Test															
Pumping level 50 ft. below surface															
Pumping at 10 GP M for 10 Hrs.															
Pumping Method ? Test Pump															
11. Well Is															
14 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? No															
Filled & Sealed Well(s) as needed? No															
13. Constructor / Supervisory Driller															
FS				Lic # 4207		Date Signed 10-12-2024									
Drill Rig Operator				Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	=	40	POWTS dispersal component (soil absorption unit or mound)	>	120

Comment:

Created On: 12-06-2024

Updated On: 04-21-2025

Review Status: APPROVED