Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZP288

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BOE, JEROME			Phone #
Mailing Address: 1209 21 3/4 ST			
City: CAMERON	State: WI	Zip Code: 54822	
County: Barron	Co. Permit #:	Notification #: 8938229102	Completed: 12-01-2022

Well Constructor (Business Name): RUTHERFORD WELL DRLG INC	Lic. #: 6764	Facility ID # (Public Wells):	
Address: 2422 27 1/2 AVE RICE LAKE WI 54868		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.5	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of STANLEY

Fire # (if avail.): 1209

Street Address or Road Name and Number: 21 3/4 ST

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
45.3809 °N -91.7136 °W	SCR002

SW	SE	Section	Township	Range
or Govt Lot #		34	34 N	11 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	52

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		I-SOIL-ORGANIC	Surface	2
T		G	S	T-TAN/BROWN G-GRAVEL/STONES S-SANDY	2	20
G		C	S	G-GRAY C-CLAY S-SANDY	20	32
K		Y		K-BLACK Y-SAND & GRAVEL	32	42
T		S		T-TAN/BROWN S-SAND	42	52

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	WHEATLAND ASTM A53 10.97 T&C	Surface	48
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
4	STAINLESS #15 SLOTTED	48	52

7. Grout or Other Sealing Material

Method BENTONITE MOUNDED

9. Static Water Level

20 ft. below ground surface

10. Pump Test

Pumping level 42 ft. below surface
Pumping at 10 GP M for 8 Hrs.
Pumping Method ? Test Pump

11. Well Is

22 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
WERE NONE

Filled & Sealed Well(s) as needed? No
WERE NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
TRS	4719	12-26-2022
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MR	9049	12-26-2022

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)		100	Sewer - Building Sanitary		55
POWTS dispersal component (soil absorption unit or mound)		80	Septic or Holding, or POWTS Tank		75

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	12/01/2022	WATER TEST IN SPRING 2023 WHEN HOME IS MORE COMPLETE

Created On: 01-19-2023 Updated On: 08-16-2023 Review Status: APPROVED