

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZP787		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner BERKSHIRE, JEFF						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address N905 LUCERNE TERRACE DR						Town of MARION						N905							
City NESHKORO						State WI		Zip Code 54960				Street Address or Road Name and Number N905 LUCERNE TERRACE DR							
County Waushara		Co. Permit #		Notification # 9022355801		Completed 12-16-2022		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) SCHAFFER R J & SONS INC				Lic. # 177		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.0122 °N -89.2105 °W				Method Code GPS008					
Address 520 WAUPACA ST FREMONT WI 54940				Well Plan Approval #		SE SE		Section 20		Township 18 N		Range 11 E		or Govt Lot #					
Approval Date (mm-dd-yyyy)				Hicap Permanent Well #		Common Well #		Specific Capacity 0.3				2. Well Type Replacement							
Hicap Property ? No				Hicap Potable ? No		Reason for replaced or reconstructed well ? LOW YIELD				Construction Type Drilled									
3. Well serves 1 # of HOME				Private, potable		Heat Exchange ___ # of drillholes				of previous unique well # constructed in									
4. Potential Contamination Sources - ON REVERSE SIDE				5. Drillhole Dimensions and Construction Method		8. Geology				11. Well Is									
Dia. (in.) 8.75		From (ft.) Surface		To (ft.) 97		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
Yes		Rotary - Mud Circulation		No		M				S		C		Z-CLAY & GRAVEL S-SANDY		Surface		67	
No		Rotary - Air		No		Z				S		C		M-MEDIUM S-SAND C-CLAYEY		67		75	
No		Rotary - Air & Foam		No		Y				S		C		Z-CLAY & GRAVEL S-SANDY		75		86	
No		Drill-Through Casing Hammer		No		Y				S		C		Y-SAND & GRAVEL		86		97	
No		Reverse Rotary		No		Pumping level 90 ft. below surface				Pumping at 15 GP M for 3 Hrs.				Pumping Method ? Airlift					
No		Cable-tool Bit ___ in. dia...		No		Pumping Method ? Airlift				Pumping Method ? Airlift				Pumping Method ? Airlift					
No		Dual Rotary		No		Pumping Method ? Airlift				Pumping Method ? Airlift				Pumping Method ? Airlift					
No		Temp. Outer Casing ___ in. dia		No		Pumping Method ? Airlift				Pumping Method ? Airlift				Pumping Method ? Airlift					
No		Removed? ___ depth ft. (If NO explain on back side)		No		Pumping Method ? Airlift				Pumping Method ? Airlift				Pumping Method ? Airlift					
6. Casing, Liner, Screen						9. Static Water Level						11. Well Is							
Dia. (in.) 5		Material, Weight, Specification CRESTLINE SDR21 PVC ASTM F-480 SOLVENT WELD CASING		From (ft.) Surface		To (ft.) 93		33 ft. below ground surface				18 in. above grade							
Dia. (in.) 5		Screen type, material & slot size X4X15 SLOT STAINLESS STEEL		From (ft.) 93		To (ft.) 97		Developed ? Yes				Disinfected ? Yes							
Dia. (in.) 5		Screen type, material & slot size X4X15 SLOT STAINLESS STEEL		From (ft.) 93		To (ft.) 97		Capped ? Yes				Capped ? Yes							
7. Grout or Other Sealing Material						12. Notified Owner of need to fill & seal ?						13. Constructor / Supervisory Driller							
Method TREMIE PIPE - PUMPED						Filled & Sealed Well(s) as needed?						Lic # 643							
Kind of Sealing Material QUIK GROUT		From (ft.) Surface		To (ft.) 90		# Sacks Cement 9 S		Date Signed 12-28-2022				Date Signed							
Kind of Sealing Material GRAVEL PACK		From (ft.) 90		To (ft.) 97		# Sacks Cement 12 S		Date Signed				Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		85	Septic or Holding, or POWTS Tank		65

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	12/16/2022	WATER SAMPLE WILL BE DELAYED. NO PUMP INSTALLED AT THIS TIME.

Created On: 01-19-2023

Updated On: 09-29-2023

Review Status: APPROVED