Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZP967

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PETERSON, NATE	Phone #: (952)451-3360
Mailing Address: 7057 SE LAKE BLVD	
City: LAKE NEBAGAMON	State: WI — Zip Code: 54849
County: Douglas	Co. Permit #:
Notification #: 8931365501	Completed: 10-28-2022
Well Constructor (Business Name): HOLLY, WAYNE	Lic. #: 7218
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: WAYNE HOLLY WELL DRILLING 71385 HOOVER LINE IRON RIVER WI 54847	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.5	

1. Well Location

Village of LAKE NEBAGAMON	Fire # (if avail.): 6896
Street Address or Road Name and Number: S CLEVELAND RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 46.5031 °N -91.7151 °W	Method Code: GPS008
SE SW or Govt Lot #:	Section: 35 — Township: 47 N — Range: 11 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME`

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	77

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		P		P-HARDPAN	Surface	10
		G	S	G-GRAVEL/STONES S-SANDY	10	60
T	A	S		T-TAN/BROWN A-COARSE S-SAND	60	77

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	PVC SDR21 NORTH AMERICAN SPECIALTY STM F-480 GLUE	Surface	73
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3	SS FLATBOTTOM 10 SLOT	73	77

7. Grout or Other Sealing Material

Method PUMP

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
EZ SEAL BENTONITE	Surface	65	6 S

9. Static Water Level

40 ft. below ground surface

10. Pump Test

Pumping level 68 ft. below surface

Pumping at 15 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
WH	7218	10-28-2022
Drill Rig Operator	Lic or Reg #	Date Signed
DH	8983	10-28-2022

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		65

Comment:

Created On: 12-05-2022 Updated On: 08-14-2023 Review Status: APPROVED