

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZP967		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner PETERSON, NATE				Phone # (952)451-3360		1. Well Location				Fire # (if avail.)	
Mailing Address 7057 SE LAKE BLVD						Village of LAKE NEBAGAMON				6896	
City LAKE NEBAGAMON				State WI		Zip Code 54849				Street Address or Road Name and Number	
S CLEVELAND RD						Subdivision Name				Lot #	
Block #						Latitude / Longitude in Decimal Degree (DD)				Method Code	
46.5031 °N -91.7151 °W						GPS008					
SE SW Section Township Range or Govt Lot # 35 47 N 11 W						2. Well Type New Well					
of previous unique well #						constructed in					
Reason for replaced or reconstructed well ?						Construction Type Drilled					
Well Constructor (Business Name) HOLLY, WAYNE				Lic. # 7218		Facility ID # (Public Wells)					
Address WAYNE HOLLY WELL DRILLING 71385 HOOVER LINE IRON RIVER WI 54847				Well Plan Approval #		Approval Date (mm-dd-yyyy)					
Hicap Permanent Well #				Common Well #		Specific Capacity 0.5					
3. Well serves 1 # of HOME`				Hicap Well ? No		Hicap Property ? No				Hicap Potable ? No	
Private,potable						Heat Exchange ___ # of drillholes					
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock		
9		Surface		77		Yes Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)					
8. Geology											
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
P		P-HARDPAN				Surface		10			
G S		G-GRAVEL/STONES S-SANDY				10		60			
T A S		T-TAN/BROWN A-COARSE S-SAND				60		77			
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)			
5		PVC SDR21 NORTH AMERICAN SPECIALTY STM F-480 GLUE				Surface		73			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
3		SS FLATBOTTOM 10 SLOT				73		77			
7. Grout or Other Sealing Material											
Method PUMP											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement					
EZ SEAL BENTONITE		Surface		65		6 S					
9. Static Water Level											
40 ft. below ground surface											
10. Pump Test											
Pumping level 68 ft. below surface											
Pumping at 15 GP M for 1 Hrs.											
Pumping Method ? Test Pump											
11. Well Is											
20 in. above grade											
Developed ? Yes											
Disinfected ? Yes											
Capped ? Yes											
12. Notified Owner of need to fill & seal ? No											
Filled & Sealed Well(s) as needed? No											
13. Constructor / Supervisory Driller											
Lic #		Date Signed									
WH		7218		10-28-2022							
Drill Rig Operator		Lic or Reg #		Date Signed							
DH		8983		10-28-2022							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		65

Comment:

Created On: 12-05-2022

Updated On: 08-14-2023

Review Status: APPROVED