

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZP970		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner DZIKONSKI, STAN						Phone # (715)817-0035		1. Well Location				Fire # (if avail.)	
Mailing Address 6921 S PEARSON RD						Town of AMNICON						8319	
City SOUTH POINTE						State WI		Zip Code 54874				Street Address or Road Name and Number	
US HWY 2						Subdivision Name				Lot #		Block #	
County Douglas		Co. Permit #		Notification # 8938912401		Completed 11-04-2022		Latitude / Longitude in Decimal Degree (DD)				Method Code	
Well Constructor (Business Name) HOLLY, WAYNE				Lic. # 7218		Facility ID # (Public Wells)		46.6062 °N -91.8709 °W		GPS008			
Address WAYNE HOLLY WELL DRILLING 71385 HOOVER LINE IRON RIVER WI 54847				Well Plan Approval #		SE SE		Section 28		Township 48 N		Range 12 W	
Approval Date (mm-dd-yyyy)						2. Well Type Replacement							
Hicap Permanent Well #				Common Well #		Specific Capacity 0.1		of previous unique well # constructed in					
3. Well serves 1 # of HOME				Hicap Well ? No		Reason for replaced or reconstructed well ?							
Private, potable				Hicap Property ? No		INADEQUATE WATER							
Heat Exchange ___ # of drillholes				Hicap Potable ? No		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock			
9		Surface		42		<u>Yes</u> Rotary - Mud Circulation				<u>No</u>			
6		42		300		<u>No</u> Rotary - Air				<u>Yes</u>			
						<u>No</u> Rotary - Air & Foam				<u>No</u>			
						<u>No</u> Drill-Through Casing Hammer							
						<u>No</u> Reverse Rotary							
						<u>No</u> Cable-tool Bit ___ in. dia...				<u>No</u>			
						<u>No</u> Dual Rotary				<u>No</u>			
						<u>No</u> Temp. Outer Casing ___ in. dia							
						<u>No</u> Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)							
R C		R-RED C-CLAY		Surface		20							
R P		R-RED P-HARDPAN		20		27							
R B		R-RED B-BASALT OR TRAP ROCK		27		300							
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		PLAIN END STEEL ASTM A53/ASME SA53 SCHED 40 EXLTUBE WELD				Surface		42					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method PUMP													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
PORTLAND CEMENT				Surface		42		8 S					
9. Static Water Level													
30 ft. below ground surface													
10. Pump Test													
Pumping level 200 ft. below surface													
Pumping at 17 GP M for 2 Hrs.													
Pumping Method ? Airlift													
11. Well Is													
12 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ? Yes													
Filled & Sealed Well(s) as needed? No													
HOMEOWNER UNCERTAIN IF THEY WANT OLD WELL ABANDONED AT THIS POINT													
13. Constructor / Supervisory Driller				Lic #		Date Signed							
WH				7218		11-04-2022							
Drill Rig Operator				Lic or Reg #		Date Signed							
DH				8983		11-04-2022							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		300

Comment:

Created On: 12-02-2022

Updated On: 09-29-2023

Review Status: APPROVED