Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZP970

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: DZIKONSKI, STAN		Phone #: (715)817-0035
Mailing Address: 6921 S PEARSON RD		
City: SOUTH POINTE	State: WI	Zip Code: 54874
County: Douglas	Co. Permit #:	Notification #: 8938912401 / Completed: 11-04-2022

1. Well Location

Fire # (if avail.): 8319

Town of AMNICON

Street Address or Road Name and Number: US HWY 2

Subdivision Name: | Lot #: | Block #:

Well Constructor (Business Name): HOLLY, WAYNE	Lic. #: 7218	Facility ID # (Public Wells):	Latitude / Longitude in Decimal Degree (DD): 46.6062 °N -91.8709 °W	Method Code: GPS008
Address: WAYNE HOLLY WELL DRILLING 71385 HOOVER LINE IRON RIVER WI 54847		Well Plan Approval #:	SE SE or Govt Lot #:	Section: 28 / Township: 48 N / Range: 12 W
		Approval Date (mm-dd-yyyy):		
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.1		

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: INADEQUATE WATER

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	42
6	42	300

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R		C		R-RED C-CLAY	Surface	20
R		P		R-RED P-HARDPAN	20	27
R		B		R-RED B-BASALT OR TRAP ROCK	27	300

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	PLAIN END STEEL ASTM A53/ASME SA53 SCHED 40 EXLTUBE WELD	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

30 ft. below ground surface

10. Pump Test

Pumping level 200 ft. below surface

Pumping at 17 GP M for 2 Hrs.

Pumping Method ? Airlift

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method PUMP

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PORTLAND CEMENT	Surface	42	8 S

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? No

HOMEOWNER UNCERTAIN IF THEY WANT OLD WELL ABANDONED AT THIS POINT

13. Constructor / Supervisory Driller	Lic #	Date Signed
WH	7218	11-04-2022
Drill Rig Operator	Lic or Reg #	Date Signed
DH	8983	11-04-2022

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		300

Comment:

Created On: 12-02-2022 Updated On: 09-29-2023 Review Status: APPROVED