Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZP971

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: TEKIPPE, EARL & DAVID		Phone #: (218)428-8442
Mailing Address: 9202 E MOONSHINE RD PO BOX 1723		
City: SUPERIOR	State: WI	Zip Code: 54880

County	Co. Permit #	Notification #	Completed
Douglas		8939932401	10-28-2022

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
HOLLY, WAYNE	7218	

Address: WAYNE HOLLY WELL DRILLING 71385 HOOVER LINE, IRON RIVER WI 54847

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well #	Common Well #	Specific Capacity
		0

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location
Town of AMNICON

Fire # (if avail.): 9202

Street Address or Road Name and Number: E MOONSHINE RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
46.6185 °N	-91.8241 °W			GPS008

NW or Govt Lot #	NW	Section	Township	Range
		25	48 N	12 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	42
6	42	300

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R		C		R-RED C-CLAY	Surface	15
R	B	P		R-RED B-BROKEN P-HARDPAN	15	25
U		B		U-BLUE B-BASALT OR TRAP ROCK	25	300

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	PLAIN END STEEL ASTM A53/ASME SA53 SCHED 40 EXLTUBE WELD	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
30 ft. below ground surface

10. Pump Test
Pumping level 280 ft. below surface
Pumping at 0.5 GP M for 3 Hrs.
Pumping Method ? Airlift

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method PUMP

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PORTLAND CEMENT	Surface	42	8 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
WH	7218	10-28-2022
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DH	8983	10-28-2022

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		55

Comment:

Created On: 12-05-2022 Updated On: 08-11-2023 Review Status: APPROVED