

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZP973		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner RANTALA, CLIFFORD						Phone # (715)742-3215		1. Well Location				Fire # (if avail.)									
Mailing Address PO BOX 336						Town of BELL						86715									
City CORNUCOPIA						State WI		Zip Code 54827				Street Address or Road Name and Number									
County Bayfield						Co. Permit #		Notification # 8948998601		Completed 11-14-2022		CO HWY C									
Well Constructor (Business Name) HOLLY, WAYNE						Lic. # 7218		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 46.8287 °N -91.0972 °W		Method Code GPS008									
Address WAYNE HOLLY WELL DRILLING 71385 HOOVER LINE IRON RIVER WI 54847						Well Plan Approval #		SE NE Section Township Range or Govt Lot # 10 50 N 6 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled											
						Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #				Common Well #		Specific Capacity															
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ? No															
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
9		Surface		200		<u>Yes</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>No</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)								N S M N-FINE S-SAND M-SILTY R P R-RED P-HARDPAN N S M N-FINE S-SAND M-SILTY T A S T-TAN/BROWN A-COARSE S-SAND T P T-TAN/BROWN P-HARDPAN N S N-FINE S-SAND N S N-FINE S-SAND		Surface 100 110 130 138 170 175 200					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		180 ft. below ground surface				20 in. above grade							
5		PVC SDR17 NORTH AMERICAN SPECIALTY ASTM F-480 GLUE				Surface		192		10. Pump Test Pumping level 180 ft. below surface Pumping at 12 GP M for 3 Hrs. Pumping Method ? Test Pump				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)													
3		SS FLAT BOTTOM 10 SLOT				192		200													
7. Grout or Other Sealing Material Method TREMIE PIPE - PUMPED														12. Notified Owner of need to fill & seal ? No							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No											
EZ SEAWL BENTONITE				Surface		184		18 S													
13. Constructor / Supervisory Driller														Lic #		Date Signed					
WH														7218		11-14-2022					
Drill Rig Operator														Lic or Reg #		Date Signed					
DH														8983		11-14-2022					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		45

Comment:

Created On: 01-19-2023

Updated On: 08-03-2023

Review Status: APPROVED