Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZP973

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: RANTALA, CLIFFORD		Phone #: (715)742-3215
Mailing Address: PO BOX 336		
City: CORNUCOPIA	State: WI	Zip Code: 54827

County	Co. Permit #	Notification #	Completed
Bayfield		8948998601	11-14-2022

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
HOLLY, WAYNE	7218	

Address: WAYNE HOLLY WELL DRILLING 71385 HOOVER LINE, IRON RIVER WI 54847

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well # | Common Well # | Specific Capacity

1. Well Location

Fire # (if avail.): 86715

Town of BELL

Street Address or Road Name and Number: CO HWY C

Subdivision Name | Lot # | Block #

Latitude / Longitude in Decimal Degree (DD): 46.8287 °N -91.0972 °W

Method Code: GPS008

SE NE or Govt Lot #	Section	Township	Range
	10	50 N	6 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	200

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	N	S	M	N-FINE S-SAND M-SILTY	Surface	100
R		P		R-RED P-HARDPAN	100	110
	N	S	M	N-FINE S-SAND M-SILTY	110	130
T	A	S		T-TAN/BROWN A-COARSE S-SAND	130	138
T		P		T-TAN/BROWN P-HARDPAN	138	170
	N	S		N-FINE S-SAND	170	175
	N	S		N-FINE S-SAND	175	200

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	PVC SDR17 NORTH AMERICAN SPECIALTY ASTM F-480 GLUE	Surface	192
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3	SS FLAT BOTTOM 10 SLOT	192	200

7. Grout or Other Sealing Material

Method: TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
EZ SEAWL BENTONITE	Surface	184	18 S

9. Static Water Level

180 ft. below ground surface

10. Pump Test

Pumping level 180 ft. below surface

Pumping at 12 GP M for 3 Hrs.

Pumping Method ? Test Pump

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
WH	7218	11-14-2022
Drill Rig Operator	Lic or Reg #	Date Signed
DH	8983	11-14-2022

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		45

Comment:

Created On: 01-19-2023 Updated On: 08-03-2023 Review Status: APPROVED