Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZQ440

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FIFIELD, TIM			Phone #: (920)373-1942
Mailing Address: 7644 CTY V			
City: GILLETT	State: WI	Zip Code: 54124	
County: Oconto	Co. Permit #:	Notification #: 9869752901	Completed: 05-28-2025

Well Constructor (Business Name): YOUNG, RAYMOND JR	Lic. #: 455	Facility ID # (Public Wells):
Address: CHICKEN YOUNGS WELL DRILLING 9584 ROSE RD GILLETT WI 54124-9587		Well Plan Approval #:
		Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.3

3. Well serves # of SHOP
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location
Town of HOW
Fire # (if avail.): 7488
Street Address or Road Name and Number: RED BANK RD
Subdivision Name:
Lot #:
Block #:
Latitude / Longitude in Decimal Degree (DD): 44.9493 °N -88.4268 °W
Method Code: GPS008
NW SW or Govt Lot #
Section: 34
Township: 29 N
Range: 17 E

2. Well Type New Well
of previous unique well #
constructed in
Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	263

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		S-SAND	Surface	20
		X		X-SAND & CLAY	20	255
		G		G-GRAVEL/STONES	255	263

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEELAND ASTM A53 WELDED	Surface	263
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		12 S

9. Static Water Level
45 ft. below ground surface

10. Pump Test
Pumping level 100 ft. below surface
Pumping at 15 GP M for 24 Hrs.
Pumping Method ? Test Pump

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
RY	455	05-28-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 07-01-2025 Updated On: 07-01-2025 Review Status: APPROVED