

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZQ440		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner FIFIELD, TIM				Phone # (920)373-1942		1. Well Location				Fire # (if avail.)	
Mailing Address 7644 CTY V						Town of HOW				7488	
City GILLETT				State WI Zip Code 54124		Street Address or Road Name and Number RED BANK RD					
County Oconto		Co. Permit #		Notification # 9869752901		Completed 05-28-2025		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) YOUNG, RAYMOND JR				Lic. # 455		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.9493 °N -88.4268 °W		Method Code GPS008	
Address CHICKEN YOUNGS WELL DRILLING 9584 ROSE RD GILLETT WI 54124-9587				Well Plan Approval #		NW SW Section Township Range or Govt Lot # 34 29 N 17 E		2. Well Type New Well			
Hicap Permanent Well #				Common Well #		Specific Capacity 0.3		Reason for replaced or reconstructed well ?			
3. Well serves # of SHOP				Hicap Well ? No		Private, potable		Hicap Property ? No		Construction Type Drilled	
Heat Exchange ___ # of drillholes				Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock		
6		Surface		263		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)					
8. Geology											
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
S		S-SAND				Surface		20			
X		X-SAND & CLAY				20		255			
G		G-GRAVEL/STONES				255		263			
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)			
6		WHEELAND ASTM A53 WELDED				Surface		263			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
7. Grout or Other Sealing Material											
Method MOUNDED											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement					
GRANULAR BENTONITE		Surface				12 S					
9. Static Water Level											
45 ft. below ground surface											
10. Pump Test											
Pumping level 100 ft. below surface											
Pumping at 15 GP M for 24 Hrs.											
Pumping Method ? Test Pump											
11. Well Is											
24 in. above grade											
Developed ? Yes											
Disinfected ? Yes											
Capped ? Yes											
12. Notified Owner of need to fill & seal ? No											
Filled & Sealed Well(s) as needed? No											
13. Constructor / Supervisory Driller											
Lic #		Date Signed									
RY		455		05-28-2025							
Drill Rig Operator		Lic or Reg #		Date Signed							

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 07-01-2025

Updated On: 07-01-2025

Review Status: APPROVED