Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZQ441

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SCHENKOSKI, GARY	Phone #: (715)373-6658
Mailing Address: 9668 SANDY CORNERS	
City: GILLETT	State: WI — Zip Code: 54124

County	Co. Permit #	Notification #	Completed
Oconto		9929178501	06-30-2025

Well Constructor (Business Name): YOUNG, RAYMOND JR	Lic. #: 455
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: CHICKEN YOUNGS WELL DRILLING 9584 ROSE RD GILLETT WI 54124-9587	Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well # — Specific Capacity

1. Well Location

Town of OCONTO FALLS	Fire # (if avail.): 9668
Street Address or Road Name and Number: SANDY CORNERS	
Subdivision Name	Lot # — Block #
Latitude / Longitude in Decimal Degree (DD): 44.8746 °N -88.2455 °W	Method Code: GPS008

SW	NW	Section	Township	Range
or Govt Lot #		30	28 N	19 E

2. Well Type Replacement

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?
BAD WATER

Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	125

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		S-SAND	Surface	65
		S	C	S-SAND C-CLAYEY	65	103
		N		N-SANDSTONE	103	125

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND ASTM A53 WELDED	Surface	103
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		4 S

9. Static Water Level
2 ft. above ground surface

10. Pump Test
Pumping level 1 ft. below surface
Pumping at 20 GP M for 24 Hrs.
Pumping Method ? Test Pump

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes
PLUMBER

13. Constructor / Supervisory Driller	Lic #	Date Signed
RY	455	06-30-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		130	Septic or Holding, or POWTS Tank		36

Comment:

Created On: 07-22-2025 Updated On: 07-13-2026 Review Status: APPROVED