

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZQ441		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner SCHENKOSKI, GARY						Phone # (715)373-6658		1. Well Location				Fire # (if avail.)		
Mailing Address 9668 SANDY CORNERS						Town of OCONTO FALLS						9668		
City GILLETT						State WI		Zip Code 54124				Street Address or Road Name and Number SANDY CORNERS		
County Oconto		Co. Permit #		Notification # 9929178501		Completed 06-30-2025		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) YOUNG, RAYMOND JR				Lic. # 455		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.8746 °N -88.2455 °W			Method Code GPS008	
Address CHICKEN YOUNGS WELL DRILLING 9584 ROSE RD GILLETT WI 54124-9587				Well Plan Approval #		SW NW		Section 30		Township 28 N		Range 19 E		
				Approval Date (mm-dd-yyyy)		or Govt Lot #								
Hicap Permanent Well #			Common Well #			Specific Capacity			2. Well Type Replacement					
Reason for replaced or reconstructed well ? BAD WATER														
3. Well serves 1 # of HOME						Hicap Well ? No								
Private, potable						Hicap Property ? No								
Heat Exchange ___ # of drillholes						Hicap Potable ? No								
						Construction Type Drilled								
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock					
6		Surface		125		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)			
S			S-SAND						Surface		65			
S C			S-SAND C-CLAYEY						65		103			
N			N-SANDSTONE						103		125			
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6		WHEATLAND ASTM A53 WELDED				Surface		103						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
7. Grout or Other Sealing Material														
Method MOUNDED														
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement						
GRANULAR BENTONITE				Surface				4 S						
9. Static Water Level														
2 ft. above ground surface														
10. Pump Test														
Pumping level 1 ft. below surface														
Pumping at 20 GP M for 24 Hrs.														
Pumping Method ? Test Pump														
11. Well Is														
24 in. above grade														
Developed ? Yes														
Disinfected ? Yes														
Capped ? Yes														
12. Notified Owner of need to fill & seal ? Yes														
Filled & Sealed Well(s) as needed? Yes														
PLUMBER														
13. Constructor / Supervisory Driller						Lic #		Date Signed						
RY						455		06-30-2025						
Drill Rig Operator						Lic or Reg #		Date Signed						

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		130	Septic or Holding, or POWTS Tank		36

Comment:

Created On: 07-22-2025

Updated On: 07-13-2026

Review Status: APPROVED