

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZQ442		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner RASMUSSEN, WYATT						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address N7188 GREEN VALLEY RD						Town of GREEN VALLEY						N7188			
City OCONTO FALLS						State WI		Zip Code 54154				Street Address or Road Name and Number GREEN VALLEY RD			
County Shawano		Co. Permit #		Notification # 9958510501		Completed 08-07-2025		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) YOUNG, RAYMOND JR				Lic. # 455		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.84839 °N -88.2686 °W				Method Code GPS008	
Address CHICKEN YOUNGS WELL DRILLING 9584 ROSE RD GILLETT WI 54124-9587				Well Plan Approval #		SW NW Section Township Range or Govt Lot # 1 27 N 18 E		2. Well Type Replacement				of previous unique well # constructed in			
Hicap Permanent Well #		Common Well #		Specific Capacity 0.4		Reason for replaced or reconstructed well ? NO WATER				Construction Type Drilled					
3. Well serves 1 # of HOME				Hicap Well ? No		Private, potable				Hicap Property ? No					
Heat Exchange ___ # of drillholes				Hicap Potable ? No											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
8.75		Surface		46		Yes Rotary - Mud Circulation				No					
6		46		140		No Rotary - Air				Yes					
						No Rotary - Air & Foam				No					
						No Drill-Through Casing Hammer									
						No Reverse Rotary									
						No Cable-tool Bit ___ in. dia...				No					
						No Dual Rotary				No					
						No Temp. Outer Casing ___ in. dia									
						No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
S C				S-SAND C-CLAYEY				Surface		46					
L				L-LIMESTONE/DOLOMITE				46		100					
N				N-SANDSTONE				100		140					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		WHEATLAND A-53				Surface		46							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method TREMIE PIPE - PUMPED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
HIGH SOLIDS BENTONITE				Surface		46		4 S							
9. Static Water Level															
53 ft. below ground surface															
10. Pump Test															
Pumping level 130 ft. below surface															
Pumping at 30 GP M for 0.5 Hrs.															
Pumping Method ? Airlift															
11. Well Is															
24 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? Yes															
Filled & Sealed Well(s) as needed? Yes															
PLUMBER TO DO															
13. Constructor / Supervisory Driller				Lic #		Date Signed									
RY				455		08-07-2025									
Drill Rig Operator				Lic or Reg #		Date Signed									
LA				7408		08-07-2025									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		54	POWTS dispersal component (soil absorption unit or mound)		65

Comment:

Created On: 10-23-2025

Updated On: 10-23-2025

Review Status: APPROVED