Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZQ442

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RASMUSSEN, WYATT			Phone #
Mailing Address: N7188 GREEN VALLEY RD			
City: OCONTO FALLS	State: WI	Zip Code: 54154	
County: Shawano	Co. Permit #:	Notification #: 9958510501	Completed: 08-07-2025

1. Well Location

Town of GREEN VALLEY

Fire # (if avail.): N7188

Street Address or Road Name and Number: GREEN VALLEY RD

Subdivision Name | Lot # | Block #

Well Constructor (Business Name): YOUNG, RAYMOND JR	Lic. #: 455	Facility ID # (Public Wells)	Latitude / Longitude in Decimal Degree (DD): 44.84839 °N -88.2686 °W
		Well Plan Approval #	Method Code: GPS008
Address: CHICKEN YOUNGS WELL DRILLING 9584 ROSE RD GILLETT WI 54124-9587		Approval Date (mm-dd-yyyy)	SW NW or Govt Lot #; Section: 1; Township: 27 N; Range: 18 E
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.4	

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: NO WATER

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	46
6	46	140

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S	C	S-SAND C-CLAYEY	Surface	46
		L		L-LIMESTONE/DOLOMITE	46	100
		N		N-SANDSTONE	100	140

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND A-53	Surface	46
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
HIGH SOLIDS BENTONITE	Surface	46	4 S

9. Static Water Level

53 ft. below ground surface

10. Pump Test

Pumping level 130 ft. below surface

Pumping at 30 GP M for 0.5 Hrs.

Pumping Method ? Airlift

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

PLUMBER TO DO

13. Constructor / Supervisory Driller	Lic #	Date Signed
RY	455	08-07-2025
Drill Rig Operator	Lic or Reg #	Date Signed
LA	7408	08-07-2025

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		54	POWTS dispersal component (soil absorption unit or mound)		65

Comment:

Created On: 10-23-2025 Updated On: 10-23-2025 Review Status: APPROVED