Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZQ480

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: COEL, STEVE	Phone #: (920)366-9234
Mailing Address: 3004 WHITE CLAY LAKE DR	
City: CECIL	State: WI / Zip Code: 54111
County: Shawano	Co. Permit #:
Notification #: 9669555501	Completed: 11-08-2024
Well Constructor (Business Name): YOUNG, RAYMOND JR	Lic. #: 455
Facility ID # (Public Wells):	
Address: CHICKEN YOUNGS WELL DRILLING 9584 ROSE RD, GILLETT WI 54124-9587	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1.3	

1. Well Location

Town of WASHINGTON	Fire # (if avail.): 2990
Street Address or Road Name and Number: WHITE CLAY LAKE DR	
Subdivision Name:	Lot #: / Block #:
Latitude / Longitude in Decimal Degree (DD): 44.813 °N -88.3887 °W	Method Code: GPS008
NE SE or Govt Lot #:	Section: 14 / Township: 27 N / Range: 17 E

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	130

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	G	C-CLAY G-W/GRAVEL/STONES	Surface	93
		N		N-SANDSTONE	93	130

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND ASTM A53 WELDED	Surface	93
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		5 S

9. Static Water Level
25 ft. below ground surface

10. Pump Test
Pumping level 40 ft. below surface
Pumping at 20 GP M for 3 Hrs.
Pumping Method ? Test Pump

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
RY	455	11-08-2024
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	=	40	POWTS dispersal component (soil absorption unit or mound)	=	55

Comment:

Created On: 12-06-2024 Updated On: 12-06-2024 Review Status: APPROVED