

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZQ480		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner COEL, STEVE				Phone # (920)366-9234		1. Well Location				Fire # (if avail.)	
Mailing Address 3004 WHITE CLAY LAKE DR						Town of WASHINGTON				2990	
City CECIL				State WI Zip Code 54111		Street Address or Road Name and Number WHITE CLAY LAKE DR					
County Shawano		Co. Permit #		Notification # 9669555501		Completed 11-08-2024		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) YOUNG, RAYMOND JR				Lic. # 455		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.813 °N -88.3887 °W		Method Code GPS008	
Address CHICKEN YOUNGS WELL DRILLING 9584 ROSE RD GILLETT WI 54124-9587				Well Plan Approval #		NE SE Section Township Range or Govt Lot # 14 27 N 17 E		2. Well Type New Well			
Hicap Permanent Well #				Common Well #		Specific Capacity 1.3		Reason for replaced or reconstructed well ?			
3. Well serves 1 # of HOME				Hicap Well ? No		Private, potable		Hicap Property ? No		Construction Type Drilled	
Heat Exchange ___ # of drillholes				Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock		
6		Surface		130		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)					
8. Geology											
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
C G		C-CLAY G-W/GRAVEL/STONES				Surface		93			
N		N-SANDSTONE				93		130			
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)			
6		WHEATLAND ASTM A53 WELDED				Surface		93			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
7. Grout or Other Sealing Material											
Method MOUNDED											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement			
GRANULAR BENTONITE				Surface				5 S			
9. Static Water Level											
25 ft. below ground surface											
10. Pump Test											
Pumping level 40 ft. below surface											
Pumping at 20 GP M for 3 Hrs.											
Pumping Method ? Test Pump											
11. Well Is											
24 in. above grade											
Developed ? Yes											
Disinfected ? Yes											
Capped ? Yes											
12. Notified Owner of need to fill & seal ? No											
Filled & Sealed Well(s) as needed? No											
13. Constructor / Supervisory Driller											
Lic #				Date Signed							
RY				455				11-08-2024			
Drill Rig Operator				Lic or Reg #				Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	=	40	POWTS dispersal component (soil absorption unit or mound)	=	55

Comment:

Created On: 12-06-2024

Updated On: 12-06-2024

Review Status: APPROVED