

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZR671		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner SCHIEWE, TIM						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address 6N262 SURREY RD								Town of LEON				N3627									
City WAYNE						State IL		Zip Code 60184				Street Address or Road Name and Number 29TH RD									
County Waushara		Co. Permit #		Notification # 7156822201		Completed 04-26-2018		Subdivision Name				Lot # Block #									
Well Constructor (Business Name) TIMOTHY J JENKS				Lic. # 4458		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.10944 °N -89.05162 °W				Method Code GPS008									
Address JENKS WELL DRILLING WILD ROSE WI 54984				Well Plan Approval #		NE NE		Section 22		Township 19 N		Range 12 E									
				Approval Date (mm-dd-yyyy)		or Govt Lot #															
Hicap Permanent Well #		Common Well #		Specific Capacity 2.7		NE NE		Section 22		Township 19 N		Range 12 E									
3. Well serves 1 # of SHED				Hicap Well ? No		NE NE		Section 22		Township 19 N		Range 12 E									
Private, potable				Hicap Property ? No		NE NE		Section 22		Township 19 N		Range 12 E									
Heat Exchange ___ # of drillholes				Hicap Potable ?		NE NE		Section 22		Township 19 N		Range 12 E									
												2. Well Type New Well									
												of previous unique well # constructed in									
												Reason for replaced or reconstructed well ?									
												Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		121		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)								T Q S -		Tan/Brown, Caving, Sand		Surface		50	
														T Q X -		Tan/Brown, Caving, Sand & Clay		50		79	
														T Q S -		Tan/Brown, Caving, Sand		79		83	
														T V C -		Tan/Brown, Non-Caving, Clay		83		92	
														T Q Z -		Tan/Brown, Caving, Clay & Gravel		92		114	
														T W Y -		Tan/Brown, Water Bearing, Sand & Gravel		114		121	
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		54 ft. below ground surface				18 in. above grade							
6		IPSCO A53B P.E. WELDED 18.97#/FT 1780 HYDRO				Surface		117		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 65 ft. below surface											
6		12 SLOT JOHNSON SS				117		121		Pumping at 30 GP M for 1 Hrs.											
										Pumping Method ?											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?							
Method MOUNDED																					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?											
CASING SEAL				Surface				1													
														13. Constructor / Supervisory Driller				Lic #		Date Signed	
														TJ				05-01-2018			
														Drill Rig Operator		Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		12

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	05/11/2018	WATER SAMPLE DELAYED, NOT HOOKED UP

Created On: 05-14-2018

Updated On: 05-14-2018

Review Status: APPROVED