Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZR672

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LIETZ, RICK	Phone #
Mailing Address: W6336 FAWN CT	
City: MONTELLO	State: WI — Zip Code: 53949
County: Marquette	Co. Permit #: — Notification #: 7158499301 — Completed: 04-27-2018
Well Constructor (Business Name): TIMOTHY J JENKS	Lic. #: 4458 — Facility ID # (Public Wells):
Address: JENKS WELL DRILLING, WILD ROSE WI 54984	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 2.1

1. Well Location

Town of PACKWAUKEE	Fire # (if avail.): W6336
Street Address or Road Name and Number: FAWN CT	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.81411 °N -89.4765 °W	Method Code: GPS007
NE NW or Govt Lot #:	Section: 6 — Township: 15 N — Range: 9 E

2. Well Type Replacement
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?: FAILED 2 IN.
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	41

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	S	-	Tan/Brown, Caving, Sand	Surface	3
R	V	C	-	Red, Non-Caving, Clay	3	21
T	N	S	M	Tan/Brown, Fine, Sand, Silty	21	30
T	W	S	-	Tan/Brown, Water Bearing, Sand	30	41

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	IPSCO A53B P.E. WELDED 18.97#/FT 1780 HYDRO	Surface	37
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	12 SLOT JOHNSON SS	37	41

9. Static Water Level
8 ft. below ground surface

10. Pump Test
Pumping level 20 ft. below surface
Pumping at 25 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
15 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CASING SEAL	Surface		0.5

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
TJ		05-04-2018
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Clearwater Sump		14
Building Overhang		4	Septic or Holding, or POWTS Tank		35

Comment:

Created On: 05-14-2018 Updated On: 04-08-2020 Review Status: APPROVED