

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZR672		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner LIETZ, RICK						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address W6336 FAWN CT						Town of PACKWAUKEE						W6336							
City MONTELLO						State WI		Zip Code 53949				Street Address or Road Name and Number							
FAWN CT						Subdivision Name				Lot #		Block #							
County Marquette		Co. Permit #		Notification # 7158499301		Completed 04-27-2018		Latitude / Longitude in Decimal Degree (DD)				Method Code							
Well Constructor (Business Name) TIMOTHY J JENKS				Lic. # 4458		Facility ID # (Public Wells)				43.81411 °N -89.4765 °W		GPS007							
Address JENKS WELL DRILLING WILD ROSE WI 54984				Well Plan Approval #		NE NW		Section 6		Township 15 N		Range 9 E							
				Approval Date (mm-dd-yyyy)		or Govt Lot #													
Hicap Permanent Well #		Common Well #		Specific Capacity 2.1		2. Well Type Replacement				of previous unique well # constructed in									
Reason for replaced or reconstructed well ?				FAILED 2 IN.				Construction Type Drilled											
3. Well serves 1 # of HOME				Hicap Well ? No		Private, potable				Hicap Property ? No									
Heat Exchange ___ # of drillholes				Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.) 6		From (ft.) Surface		To (ft.) 41		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
						No Rotary - Mud Circulation		No		T Q S -		Tan/Brown, Caving, Sand		Surface		3			
						No Rotary - Air		No		R V C -		Red, Non-Caving, Clay		3		21			
						No Rotary - Air & Foam		No		T N S M		Tan/Brown, Fine, Sand, Silty		21		30			
						No Drill-Through Casing Hammer				T W S -		Tan/Brown, Water Bearing, Sand		30		41			
						No Reverse Rotary													
						No Cable-tool Bit ___ in. dia...		No											
						No Dual Rotary		No											
						No Temp. Outer Casing ___ in. dia													
						No Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		8 ft. below ground surface				15 in. above grade					
6		IPSCO A53B P.E. WELDED 18.97#/FT 1780 HYDRO				Surface		37		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 20 ft. below surface				Disinfected ? Yes					
6		12 SLOT JOHNSON SS				37		41		Pumping at 25 GP M for 1 Hrs.				Capped ? Yes					
										Pumping Method ?									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method MOUNDED												Filled & Sealed Well(s) as needed? Yes							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed			
CASING SEAL				Surface				0.5		TJ						05-04-2018			
										Drill Rig Operator				Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		4	POWTS dispersal component (soil absorption unit or mound)		60
Septic or Holding, or POWTS Tank		35	Clearwater Sump		14

Comment:

Created On: 05-14-2018

Updated On: 04-08-2020

Review Status: APPROVED