

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZR673		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner MEYER, JEFF						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address 6050 DRAGONFLY LANE						Town of LIND						N1322									
City LYNDEN						State WA		Zip Code 98264				Street Address or Road Name and Number COUNTY ROAD E									
County Waupaca		Co. Permit #		Notification # 7172584501		Completed 05-09-2018		Subdivision Name				Lot # Block #									
Well Constructor (Business Name) TIMOTHY J JENKS				Lic. # 4458		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.28744 °N -89.00979 °W				Method Code GPS008							
Address JENKS WELL DRILLING WILD ROSE WI 54984				Well Plan Approval #		SW SW		Section 18		Township 21 N		Range 12 E									
				Approval Date (mm-dd-yyyy)		or Govt Lot #															
Hicap Permanent Well #		Common Well #		Specific Capacity 8.3		2. Well Type Replacement				of previous unique well # constructed in											
3. Well serves 1 # of HOME				Hicap Well ? No		Reason for replaced or reconstructed well ?				Construction Type Drilled											
Private, potable				Hicap Property ? No																	
Heat Exchange ___ # of drillholes				Hicap Potable ? No																	
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
5		Surface		105		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)						T Q Y - TAN/BROWN, CAVING, SAND & GRAVEL G V C - GRAY, NON-CAVING, CLAY G Q C S GRAY, CAVING, CLAY, SANDY T W Y - TAN/BROWN, WATER BEARING, SAND & GRAVEL				Surface 48 48 75 75 96 96 105					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		16 ft. below ground surface				14 in. above grade							
5		WHEATLAND A53B T&C 15#/FT 1950 HYDRO				Surface		101		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 19 ft. below surface				Disinfected ? Yes							
5		12 SLOT JOHNSON SS				101		105		Pumping at 25 GP M for 2 Hrs.				Capped ? Yes							
7. Grout or Other Sealing Material														Pumping Method ?							
Method														12. Notified Owner of need to fill & seal ? No							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? Yes											
				Surface																	
														13. Constructor / Supervisory Driller				Lic #		Date Signed	
														TJ						05-11-2018	
														Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55	Building Overhang		4
			Septic or Holding, or POWTS Tank		36

Comment:

Created On: 05-17-2018

Updated On: 06-12-2018

Review Status: APPROVED