Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZR673

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: MEYER, JEFF	Phone #
Mailing Address: 6050 DRAGONFLY LANE	
City: LYNDEN	State: WA Zip Code: 98264
County: Waupaca	Co. Permit #:	Notification #: 7172584501	Completed: 05-09-2018
Well Constructor (Business Name): TIMOTHY J JENKS	Lic. #: 4458	Facility ID # (Public Wells):
Address: JENKS WELL DRILLING, WILD ROSE WI 54984	Well Plan Approval #:	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 8.3

1. Well Location

Town of LIND				Fire # (if avail.): N1322
Street Address or Road Name and Number: COUNTY ROAD E				
Subdivision Name			Lot #	Block #
Latitude / Longitude in Decimal Degree (DD): 44.28744 °N -89.00979 °W				Method Code: GPS008
SW SW or Govt Lot #	Section: 18	Township: 21 N	Range: 12 E	

2. Well Type Replacement
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
5	Surface	105

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	Y	-	TAN/BROWN, CAVING, SAND & GRAVEL	Surface	48
G	V	C	-	GRAY, NON-CAVING, CLAY	48	75
G	Q	C	S	GRAY, CAVING, CLAY, SANDY	75	96
T	W	Y	-	TAN/BROWN, WATER BEARING, SAND & GRAVEL	96	105

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	WHEATLAND A53B T&C 15#/FT 1950 HYDRO	Surface	101
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	12 SLOT JOHNSON SS	101	105

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
16 ft. below ground surface

10. Pump Test
Pumping level 19 ft. below surface
Pumping at 25 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
TJ		05-11-2018
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55

Type	Qualifier	Distance
Building Overhang		4
Septic or Holding, or POWTS Tank		36

Comment:

Created On: 05-17-2018 Updated On: 06-12-2018 Review Status: APPROVED