Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZU109

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MARR, CARLA & JAY			Phone #
Mailing Address: 3820 GIBRALTAR ROAD			
City: FISH CREEK	State: WI	Zip Code: 54212	
County: Door	Co. Permit #:	Notification #: 7449537901	Completed: 12-03-2018

Well Constructor (Business Name): EUCLIDE,WELL DRILLING INC	Lic. #: 5905	Facility ID # (Public Wells):	
Address: 2496 STONE RD STURGEON BAY WI 54235		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.4	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of GIBRALTAR					Fire # (if avail.): 3820
Street Address or Road Name and Number: GIBRALTAR ROAD					
Subdivision Name			Lot #		Block #
Latitude / Longitude in Decimal Degree (DD): 45.127 °N -87.2227 °W					Method Code: GPS008
SW	SE	Section: 28	Township: 31 N		Range: 27 E
or Govt Lot #					

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
4" WELL IN HOUSE

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	170
6	170	242

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R		L		R-RED L-LIMESTONE/DOLOMITE	Surface	242

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL P E WT 18.97 ASTM A53B ISPCO WELDED JOINT	Surface	172
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
40 ft. below ground surface

10. Pump Test
Pumping level 100 ft. below surface
Pumping at 25 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	172	65 S

12. Notified Owner of need to fill & seal ? Yes
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
ME	5905	12-28-2018
Drill Rig Operator	Lic or Reg #	Date Signed
RE	7340	12-28-2018

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 11-10-2018 Updated On: 10-15-2026 Review Status: APPROVED