Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZV163

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GLAU, ROBERT			Phone #
Mailing Address: 86805 CLOVER CEMETERY RD			
City: HERBSTER	State: WI	Zip Code: 54844	
County: Bayfield	Co. Permit #:	Notification #: 8405666301	Completed: 02-13-2019

Well Constructor (Business Name): TRAUT MARK J WELLS INC	Lic. #: 5912	Facility ID # (Public Wells):	
Address: PO BOX 547 WAITE PARK MN 56387-0547		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.5	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of CLOVER				Fire # (if avail.): 86805
Street Address or Road Name and Number: CLOVER CEMETERY RD				
Subdivision Name			Lot #	Block #
Latitude / Longitude in Decimal Degree (DD): 46.8298 °N -91.2286 °W				Method Code: GPS008
NE NW or Govt Lot #	Section: 10	Township: 50 N	Range: 7 W	

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	100

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 8in. dia	
No	Removed? 21depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	S	I		T-TAN/BROWN S-SOFT/LOOSE I-SOIL-ORGANIC	Surface	1
T	S	S		T-TAN/BROWN S-SOFT/LOOSE S-SAND	1	12
R	S	C		R-RED S-SOFT/LOOSE C-CLAY	12	22
T	S	Z		T-TAN/BROWN S-SOFT/LOOSE Z-CLAY & GRAVEL	22	24
R	M	C		R-RED M-MEDIUM C-CLAY	24	33
T	S	Y		T-TAN/BROWN S-SOFT/LOOSE Y-SAND & GRAVEL	33	39
R	M	C		R-RED M-MEDIUM C-CLAY	39	51
K	H	K		K-BLACK H-HARD/FIRM K-COBBLES/BOULDERS	51	52
R	M	C		R-RED M-MEDIUM C-CLAY	52	100

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
8	BLACK STEEL 0.365	Surface	21
4	PVC SDR 21	0	34
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STAINLESS STEEL TELESCOPE	34	38

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	24	7 S
GRAVEL PACK	24	39	15 S
NEAT CEMENT GROUT	39	100	20 S

9. Static Water Level	11. Well Is
5 ft. above ground surface	12 in. above grade
10. Pump Test	Developed ? Yes
Pumping level 34 ft. below surface	Disinfected ? Yes
Pumping at 15 GP M for 5.5 Hrs.	Capped ? Yes
Pumping Method ? Airlift	

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? No

NO

13. Constructor / Supervisory Driller	Lic #	Date Signed
MJT	5911	02-13-2019
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RT	7333	02-13-2019

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)		30	POWTS holding component (also known as holding tank)		150
			Sewer - Building Sanitary		150

Comment:

Created On: 05-13-2021 Updated On: 05-13-2021 Review Status: APPROVED