

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ZV167		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner JACOBS WELL SITE						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 3211 N 50TH AVE						Village of LAKE HALLIE							
City LAKE HALLIE						State WI		Zip Code 54729					
County Chippewa		Co. Permit #		Notification #		Completed 10-02-2020		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) TRAUT MARK J WELLS INC				Lic. # 5912		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.8606 °N -91.4162 °W				Method Code GPS008	
Address PO BOX 547 WAITE PARK MN 56387-0547				Well Plan Approval #		SW SE Section Township Range or Govt Lot # 36 28 N 9 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled					
				Approval Date (mm-dd-yyyy)									
Hicap Permanent Well #		Common Well #		Specific Capacity 1.1									
3. Well serves # of EXPLORATION / TEST WELL Non-community Test Well						Hicap Well ? No Hicap Property ? No Hicap Potable ? No							
Heat Exchange ___ # of drillholes													
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole			Lower Open Bedrock			8. Geology				
11 Surface 20			No Rotary - Mud Circulation No			K S I K-BLACK S-SOFT/LOOSE I-SOIL-ORGANIC Surface 1							
7 20 150			No Rotary - Air No			T S S T-TAN/BROWN S-SOFT/LOOSE S-SAND 1 3							
			No Rotary - Air & Foam No			T S H N T-TAN/BROWN S-SOFT/LOOSE H-SHALE N-W/SANDSTONE 3 14							
			No Drill-Through Casing Hammer			T M H N T-TAN/BROWN M-MEDIUM H-SHALE N-W/SANDSTONE 14 72							
			No Reverse Rotary			T M H N T-TAN/BROWN M-MEDIUM H-SHALE N-W/SANDSTONE 72 74							
			No Cable-tool Bit ___ in. dia... No			T M H N T-TAN/BROWN M-MEDIUM H-SHALE N-W/SANDSTONE 74 100							
			No Dual Rotary No			T M H N T-TAN/BROWN M-MEDIUM H-SHALE N-W/SANDSTONE 100 104							
			Yes Temp. Outer Casing 11in. dia			T M H N T-TAN/BROWN M-MEDIUM H-SHALE N-W/SANDSTONE 104 135							
			Yes Removed? 150depth ft. (If NO explain on back side)			T M N G T-TAN/BROWN M-MEDIUM N-SANDSTONE G-W/GRAVEL/STONES 135 137							
						T M H N T-TAN/BROWN M-MEDIUM H-SHALE N-W/SANDSTONE 137 143							
						E H Q E-GREEN H-HARD/FIRM Q-GRANITE 143 150							
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
8		LC STEEL A53 PE CASING				Surface		20					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7		OPEN HOLE				20		150					
7. Grout or Other Sealing Material													
Method TREMIE/PUMPED													

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement	9. Static Water Level	11. Well Is
NEAT CEMENT GROUT	Surface	20	8 S	46 ft. below ground surface	24 in. above grade
				10. Pump Test	Developed ? Yes
				Pumping level 101 ft. below surface	Disinfected ? Yes
				Pumping at 60 GP M for 6 Hrs.	Capped ? Yes
				Pumping Method ? Test Pump	
				12. Notified Owner of need to fill & seal ?	
				Filled & Sealed Well(s) as needed?	No
				13. Constructor / Supervisory Driller	Lic # Date Signed
MJT				5911	10-02-2020
Drill Rig Operator				Lic or Reg #	Date Signed
DP				5911	

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 11-05-2020

Updated On: 12-18-2020

Review Status: APPROVED