Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZV169

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MAYO CLINIC HEALTH SYSTEMS			Phone #: (612)964-6197
Mailing Address: 700 WEST AVE S			
City: LA CROSSE	State: WI	Zip Code: 54601	
County: La Crosse	Co. Permit #: 8765414701	Notification #: 9029419901	Completed: 05-10-2022

1. Well Location

City of LA CROSSE

Fire # (if avail.)

Street Address or Road Name and Number: 700 WEST AVE S

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
TRAUT MARK J WELLS INC	5912	

Latitude / Longitude in Decimal Degree (DD): 43.80355 °N -91.24014 °W

Method Code: GPS008

Well Plan Approval #:

NE	NW	Section	Township	Range
or Govt Lot #		5	15 N	7 W

Address: 32640 COUNTY RD 133
SAINT JOSEPH MN 56374

Approval Date (mm-dd-yyyy):

2. Well Type New Well

of previous unique well # constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		15

Reason for replaced or reconstructed well ?

3. Well serves 0 # of TEST WELL

Private,potable Test Well

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	166

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	SCH 40 PVC, 2.1LBS/FT, ASTM F480, BELLED AND GLUED ENDS	Surface	146
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	CONTINUOUS SLOT STAINLESS STEEL 30 SLOT	146	166

7. Grout or Other Sealing Material

Method: DRILLING MUD AND CUTTINGS

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	S	F		T-TAN/BROWN S-SOFT/LOOSE F-FILL	Surface	5
T	S	S		T-TAN/BROWN S-SOFT/LOOSE S-SAND	5	20
G	H	H		G-GRAY H-HARD/FIRM H-SHALE	20	40
T	S	S		T-TAN/BROWN S-SOFT/LOOSE S-SAND	40	68
T	S	Y		T-TAN/BROWN S-SOFT/LOOSE Y-SAND & GRAVEL	68	166
T	S	S		T-TAN/BROWN S-SOFT/LOOSE S-SAND	166	166

9. Static Water Level	11. Well Is
41 ft. below ground surface	_____ in. _____Grade
10. Pump Test	Developed ? Yes
Pumping level 42 ft. below surface	Disinfected ? No
Pumping at 15 GP M for 1 Hrs.	Capped ? No
Pumping Method ? Test Pump	

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
MJT	5911	05-10-2022
Drill Rig Operator	Lic or Reg #	Date Signed
PS	7335	05-10-2022

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment: ORIGNALLY BOUGHT NOTICATION AS A HEAT EXCHANGER #8765414701. BUT SYSTEM WOULD NOT ALLOW IT SO PURCHASED NEW WELL CONSTRUCTION NOTIFICATION #9029419901.

WELL WAS USED AS A TEST WELL. INSTALLED 4" CASING WITH 20' OF STAINLESS STEEL SCREEN. DEVELOPED AND TEST PUMPED. PULLED WELL AND SEALED BORE HOLE.

TALKED WITH SARA FRY ON 6-28-23.

Abandonment Type	Abandonment Date	Procedure	Reason
	05/11/2022	14 SACKS BENTONITE CHIPS 0-166 FT	TEST WELL

Created On: 12-19-2022 Updated On: 09-08-2023 Review Status: APPROVED