Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ZZ238

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WEEKS, MICHAEL	Phone #
Mailing Address: 2000 13TH STREET	
City: LA CROSSE	State: WI Zip Code: 54601

County	Co. Permit #	Notification #	Completed
Trempealeau	20190874	7782081601	11-22-2019

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
C T W CORP	364	

Address: 21500 W GOOD HOPE RD
LANNON WI 53046-9720

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		1.2

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Fire # (if avail.): N16103

Town of GALE

Street Address or Road Name and Number: COUNTY ROAD K

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)		Method Code
44.0719 °N	-91.3741 °W	GPS008

SE SE or Govt Lot #	Section	Township	Range
	31	19 N	8 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	87

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 4in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C		C-CLAY	Surface	40
		P		P-HARDPAN	40	80
	N	S		N-FINE S-SAND	80	87

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	ASTM A53 T&C .237 WALL 11.00/FT WHEATLAND	Surface	84
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3	SS JOHNSON .015 W/ K-PACKER	84	87

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	84	1 S

9. Static Water Level
52 ft. below ground surface

10. Pump Test
Pumping level 65 ft. below surface
Pumping at 15 GP M for 1 Hrs.
Pumping Method ? Test Pump

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TS	6667	01-09-2020
Drill Rig Operator	Lic or Reg #	Date Signed
AS	8670	01-09-2020

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 01-09-2020 Updated On: 03-27-2020 Review Status: APPROVED